



Tel. No.0755-2586343  
Fax No. 0755 - 2587774  
Email: cpribpl@sancharnet.in

**CENTRAL POWER RESEARCH INSTITUTE  
GOVINDPURA : BHOPAL - 462 023**

**PROVISIONAL REPORT**

**22 FEB 2010**

**Test Report No.S2100221**

**Date of test : 19.02.2010**

1. **Customer:** M/s Alfa Automation (P) Ltd., Rourkela.
2. **Sample tested:** 50 kA, 2000A, PCC Panel
3. **Serial Number:** Nil
4. **Sample Code No.:** STDSST210S0273
5. **Type:** Nil
- 5.1 **Designation:** Nil
6. **Drawing Number:** AAPL/DRG/09-10/CPRI/A-01/097 sheet 1 of 2,  
AAPL/DRG/09-10/CPRI/A-01/097 sheet 2 of 2  
(Drawings to be revised and verified)
7. **Rating of the Sample:**
  - 7.1 **Rated Voltage :** 415 V
  - 7.2 **Rated Current :** 2000 A
  - 7.3 **Rated insulation voltage :** 690 V
  - 7.4 **Rated short time current:** 50 kArms for 1.0 second with initial peak of 105 kA
8. **Sample tested for the following ratings:**
  - 8.1 **Voltage :** 415 V
  - 8.2 **Current :** 2000 A
  - 8.3 **Insulation voltage :** 690 V
  - 8.4 **Short time current:** 50 kArms for 1.0 second with initial peak of 105 kA
  9. **Time of test carried out:** Verification of the short circuit with

10 Specification followed: VERIFICATION OF THE SHORT CIRCUIT WITHSTAND STRENGTH  
AS per cl. 8.2.3 of IS:3623 (Part-1), 1993  
11 Test results:

Oscillogram No.	Short time current in kApe/kArms			Duration in second	Equivalent current for 1.0 second in kArms
	R	Y	B		
S2100221.S02 (Three phase STC test on HBB+VBB)	105.66/50.92	50.52	50.48	1.0	50.92
S2100221.S04 (Single phase STC test on neutral & nearest phase of HBB+VBB)	65.00/30.68			1.0	30.68

**Observations:** No abnormality. Fine wire fuse intact. All busbars and supports intact.  
**Remarks:** After short circuit test the sample withstood HV test at 3.0 kVrms for one minute as per standard.

  
TEST ENGINEER

*This is only a provisional report. The final report alongwith drawings and other documents will be issued separately within one month from the date of test.*

  
LABORATORY IN-CHARGE

संयुक्त निदेशक  
Joint Director  
केन्द्रीय विद्युत अनुसंधान संस्थान  
Central Power Research Institute  
स्विचगियर परीक्षण तथा विकास केंद्र  
Switchgear Testing & Dev. Station  
गोविन्दपुरा, भोपाल-462023  
Govindpura, BHOPAL-462023